

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0801:157 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060

DESIGN: Models D411, D411LC, D412, D412LC Synchronized Control Modules.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10.5 - 31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as signaling appliances accessory for use with separately listed synchronized strobe lights. For **indoor** use only.

XLF: 7300-0785:132

*Rev. 05-31-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 31, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager